

# ADDENDUM

ADDENDUM NO: 04

PROJECT: Noblesville High School Softball Site Building

PROJECT NO: 2024079

DATE: 01/31/2025

BY: Nick Wissing

This Addendum is issued in accordance with the provisions of "The General Conditions of the Contract for Construction," Article 1, "Contract Documents" and becomes a part of the Contract Documents as provided therein. This Addendum includes:

Addendum Pages: **ADD 1 of 2 through ADD 2 of 2**

Attached Drawings: **N/A**

Attached Specifications: **N/A**

## **PART 0 - GENERAL INFORMATION**

NONE

## **PART 1 - BIDDING REQUIREMENTS**

NONE

## **PART 2 - SPECIFICATIONS**

### 2.1 09 67 23 – RESINOUS FLOORING

A. Paragraph 2.02.A – Manufacturer's, add the following

"4. Tnemec Company, Inc."

B. Paragraph 2.05.A, Eliminate the word "Precast" from "Precast, Integral Cove Base:"

## **PART 3 - DRAWINGS**

NONE

## **PART 4 - OTHER ITEMS**

NONE

## **PART 5 - QUESTIONS AND ANSWERS**

5.1 Question: Specs call out for a Duke Energy 120/208 volt 3 phase electrical service. Section 26 05 00 1.15 C – Electrical Energy Utilities. Print show a 120/240 volt single phase service. Please clarify.

- A. The service will be 120/240 volt, single phase.
- 5.2 Question: On E100 – Site Plan, you are asking to relocate the utility transformer to the south end of building, will the utility company be providing conductors in conduit from pole to transformer or is this on us?
- A. Utility provides the primary conductor to the transformer, refer to 26 05 00-1.15.C
- 5.3 Question: Does the utility meter remain in the same location or will this also be move to the south end of building.
- A. No change to the meter location.
- 5.4 Question: I was wondering how you would like us to handle the combo bid for these two jobs...do we submit the three page supplementary combination bid form in the envelope with the softball bid and also in the envelope with the middle school bid? Or do we have it in its own envelope (without a Form 96 or bid bond)? If you can clarify, I would appreciate it.
- A. You can put it in it's own envelope and you don't need any other documents with it as long as both the individual bids have all the documents accounted for.

**END ADDENDUM**