

ADDENDUM

ADDENDUM NO: 2

PROJECT: Roof Replacements for Noblesville East Middle School and Hinkle Creek Elementary School

PROJECT NO: 2025085

DATE: 04/09/2026

BY: Morganne Walker

This Addendum is issued in accordance with the provisions of "The General Conditions of the Contract for Construction," Article 1, "Contract Documents" and becomes a part of the Contract Documents as provided therein. This Addendum includes:

Addendum Pages: ADD2-1

Attached Documents: N/A

Attached Drawing Sheets: N/A

PART 0 - GENERAL INFORMATION

0.1 N/A

PART 1 - BIDDING REQUIREMENTS

1.1 N/A

PART 2 - SPECIFICATIONS

2.1 Section 07 31 13 – Asphalt Shingles

A. The following has been added to section 3.02-B:

1. 10. Underlayment: For low roof slopes of 17% to 33% slope, double underlayment application is required per building code.

PART 3 - DRAWINGS

3.1 NOT USED

PART 4 - OTHER ITEMS

4.1 NOT USED

PART 5 - QUESTIONS AND ANSWERS

5.1 NOT USED

END ADDENDUM #2